

Analysis Report

February 02, 2024

REPORT TO:

Discovery Woods
Kristi Crocker
604 N 7th Street
Brainerd MN 56401

INVOICE TO:

Discovery Woods
Kristi Crocker
604 N 7th Street
Brainerd MN 56401

Date Rcvd-Brnd: 1/18/2024

Time Rcvd-Brnd: 08:17

Sampled By: Sarah Fogderud

Sample Type: DW

Recv Temp°C: 17.4 not on ice

LOCATION:

Lead Testing

SITE / ANALYTE	Sample Date/Time	Analyzed Value	Units	Reporting Limit	Analytical Method	Analysis Date/Time	Analyst	Code #
DF1 - Bottle Filler	1/18/2024 @ 06:05							
Lead		< 1.00	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/23/24 14:44	MH	086948
Main Office - Sink	1/18/2024 @ 06:08							
Lead		1	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/23/24 14:44	MH	086949
Kindergarten - Sink	1/18/2024 @ 06:11							
Lead		5.95	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/23/24 14:44	MH	086950
DF2 - Bottle Filler	1/18/2024 @ 06:15							
Lead		< 1.00	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/22/24 11:49	SK	086951
Break Room - Sink	1/18/2024 @ 06:20							
Lead		1.3	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/23/24 14:44	MH	086952
K1 - Kitchen Sink	1/18/2024 @ 06:25							
Lead		3.94	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/23/24 14:44	MH	086953
K2 - Kitchen Sink	1/18/2024 @ 06:26							
Lead		4.17	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/23/24 14:44	MH	086954
K3 - Kitchen Sink	1/18/2024 @ 06:26							
Lead		7.16	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/23/24 14:44	MH	086955
DF3 - Bottle Filler	1/18/2024 @ 06:27							
Lead		< 1.00	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/23/24 14:44	MH	086956
Reading Classroom-Sink	1/18/2024 @ 06:28							
Lead		17.5	ug/L	1	SM 3113 B-10 (22ND ED)-PB	1/31/24 17:11	CJS	086957



Analysis Report

February 02, 2024

REPORT TO:

Discovery Woods
Kristi Crocker
604 N 7th Street
Brainerd MN 56401

INVOICE TO:

Discovery Woods
Kristi Crocker
604 N 7th Street
Brainerd MN 56401

Date Rcvd-Brnd: 1/18/2024
Time Rcvd-Brnd: 08:17

Sampled By: Sarah Fogderud
Sample Type: DW
Recv Temp°C: 17.4 not on ice

LOCATION:
Lead Testing

SITE / ANALYTE	Sample Date/Time	Analyzed Value	Units	Reporting Limit	Analytical Method	Analysis Date/Time	Analyst	Code #
----------------	------------------	----------------	-------	-----------------	-------------------	--------------------	---------	--------

Approved By:



Date Approved: 2/2/2024

Sara Ahlers, Laboratory Director

A.W. Research Laboratories, Inc. is accredited by the MNELAP and follows approved methods and procedures. MN State Laboratory ID: 027-035-135 and EPA Lab Code: MN00098. All data generated using non-accredited methods noted as -NC, and all analytes for which accreditation is unavailable -NA. The results above relate only to the samples tested. This report must not be reproduced, except in full, without the written approval of the laboratory. We appreciate your feedback, please email us at awlab@awlab.com with questions or comments. Thank you!

~End of Analysis Report~

